



THREE RELAY CONTROL WIRING TERMINALS. CONNECT TO COM & NC. DO NOT USE SOLID CORE WIRE.

RELAYS OPERATE IN "FAIL SAFE" CONFIGURATON.

INSTALLER SUPPLIED LINE VOLTAGE (90-240 VAC, 50-60 HZ)

EITHER TERMINAL CAN BE USED.

DAISY-CHAIN POWER & GND WIRES RUNNING TO ADDITIONAL ART TRANSMITTERS. NOTE THAT ONE SIGNAL WIRE MUST BE PULLED FOR EACH ADDITIONAL ART TRANSMITTER ADDED.

CRITICAL ENVIRONMENT TECHNOLOGIES CANADA INC. www.critical-environment.com

QCC TO REMOTE ART TRANSMITTER WITH QCC-RDM WIRING CONNECTION DRAWING REV-A June 20, 2016

THIS QCC + ART + QCC-RDM COMBINATION MAKES A TWO CHANNEL GAS DETECTION MONITORING SYSTEM WITH REMOTE DISPLAY FOR REFRIGERANT GAS DETECTION APPLICATIONS.